



T E S T C E R T I F I C A T E

- Product:** **Laminate floor covering „Krono Antistatik“**
Floor covering with antistatic modified
DPL-coating on HDF-Substrate
- Manufacturer:** Kronoflooring GmbH
Mühlbacher Str. 1
01561 Lampertswalde
- Order:** Test of the electrostatic behaviour of laminate floor covering
according to DIN EN 1815:1998-01 and
DIN IEC 1340-4-1: 1997-04
- Test method:** Measurement of the body voltage
in the walking test according to DIN EN 1815
- Test report:** 154461-3 dated 2003-12-04
- Test result:** In the walking test according to DIN EN 1815 in the climate
23°C / 25 % relative air humidity the body voltage was $U_p < 2$ kV.
The tested laminate floor covering shows antistatic behaviour
and fulfils the criterions for the classification as an
„Astatischer Fußboden ASF – Klasse 2“
according to DIN IEC 1340-4-1.
The laminate covering is according to prEN 14041:2001-10 an
„Antistatischer Bodenbelag“.

Dresden, 2003-12-04


Head of laboratory




Engineer in charge